



Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members

Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Gary L. Mangum
Manervia W. Riddick
James T. Smith, Jr.
Jodi C. Stanalonis

Procurement

John F. Samoryk
Vice President

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

ADDENDUM No. 3
General Contractor for Operations Office Renovations
M&T Bank Stadium
MSA Project No. 19-053

Date Issued: February 19, 2019

This Addendum is hereby made a part of the Contract Documents dated January 23, 2019 on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Bids.**

This Addendum incorporates the following items:

1. **Revised Due Date and Time:** February 22, 2019 by 2:00 p.m.
2. Questions and Answers.

a. Please advise of the deck height.

Deck height is believed to be approximately 20'-2" in the project area and consistent.

b. Please advise of the wall height for A1.02, New Construction Floor Plan Notes, #8.

Existing CMU wall on which framed wall is built is 12'-0" high.

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date