



Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members

Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Gary L. Mangum
Manervia W. Riddick
James T. Smith, Jr.
Jodi C. Stanalonis

Procurement

John F. Samoryk
Vice President

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

ADDENDUM No. 7
Replacement of Upper Concourse Ad Panels
Oriole Park at Camden Yards
MSA Project No. 19-071

Date Issued: June 24, 2019

This Addendum is hereby made a part of the Contract Documents dated April 24, 2019 on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Bids.**

This Addendum incorporates the following items:

1. Question and Answer.

What is the maximum weight or lift size allowed in area below club level signs?

The lift load in the concourses cannot exceed 100psf per axle.

Note: This is a response to the Question in Addendum No. 5 that was not answered.

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date