



Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members
.....
Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Gary L. Mangum
Carolyn Mozell
Manervia W. Riddick
Jodi C. Stanalonis

.....
Procurement

John F. Samoryk
Vice President

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

ADDENDUM No. 7
Fire Sprinkler System Modifications
M&T Bank Stadium
MSA Project No. 20-032

Date Issued: February 12, 2020

This Addendum is hereby made a part of the Contract Documents dated December 20, 2019 on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Bids.**

This Addendum incorporates the following items:

- 1. Revised Due Date for Bid:** February 20, 2020 by 2:00 p.m.
- 2. Revised Attachment B-Bid Form – Attached – dated 02/12/20.**
- 3. Questions and Answers**
- 4. Siemens Industry – Fire Alarm System Record Drawings – Attached – dated 12/14/2018**

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date

Questions and Answers:

1. Please describe how the Siemens Control Work and Programming will be incorporated into the project.

Modification of the Siemens FAS with additional SLC loops and control modules will be required for the project. Each contractor shall include this cost as part of their Base Bid. Please note that additional electrical subcontract work will be required as part of the installation of the new equipment and machinery. Refer to Bid Item # 26 of the Revised Bid Form.

2. Please provide the most recent Fire Alarm Record Documents.

A pdf copy of the Siemens Industry Record Drawings dated 12/14/2018 are attached as part of this Addendum # 07.