



**ADDENDUM No. 2
Renovations to Visitor and Auxiliary Clubhouses
Camden Yards Sports Complex
MSA Project No. 21-017**

Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members

Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Gary L. Mangum
Carolyn Mozell
Manervia W. Riddick
Jodi C. Stanalonis

Procurement

John F. Samoryk
Vice President

Date Issued: November 5, 2020

This Addendum is hereby made a part of the Contract Documents dated October 16, 2020, on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Bids.**

This Addendum incorporates the following items:

1. Questions and Answers.

Note: To register on the website of Negometrix website, go to:

<https://app.negometrix.com/registration>

Negometrix Help Desk: 724-888-5294

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

Questions and Answers

1. In the Player Kitchen A2.1, the L-shape countertop is calling out to be solid surface, do you have a manufacturer and color?

Please see the finish schedule on Drawing ID1.

2. Under the spec section 06 20 23 pg. AS.1, calls out for 5mm hole system, and the cut of the cabinet shows standards, which one should be used?

Provide the 5mm hole system called for in the specifications.

3. Is there any AV wiring or AV equipment in this bid?

The contractor shall furnish and install AV wiring. No AV equipment is NIC.

4. Where are the data outlets connected into the network?

Room 1.26.04

5. What is the height of the existing CMU walls?

Most walls go to the deck above, (+/- 16'-6" high). The contractor shall confirm all existing conditions.