



Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members

Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Gary L. Mangum
Manervia W. Riddick
Jodi C. Stanalonis

.....

Procurement

John F. Samoryk
Vice President

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

ADDENDUM No. 6
Contractor for Controls Upgrade Project
M&T Bank Stadium
MSA Project No. 21-040

Date Issued: April 15, 2021

This Addendum is hereby made a part of the Contract Documents dated March 9, 2021, on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Proposals.**

This Addendum incorporates the following items:

1. Questions and Answers
2. Damper Schedule
3. To register on the website of Negometrix website, go to:

<https://app.negometrix.com/registration>

Negometrix Help Desk: 724-888-5294

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date

Question and Answers:

- 1. It is our understanding that the intent is for an open specification. Please confirm that any BACnet-compatible field-level building automation device is acceptable that can communicate with a Schneider or Tridium / Niagara front-end. Note that this not a request for a substitution, rather it is for clarification and confirmation.**

Any BACnet compatible field level device is NOT acceptable. Per specification section 23 09 00, Section 2.1, products shall be by one of the listed pre-qualified manufacturers.

The controllers shall be manufactured by the same manufacturer as the BAS platform.

- 2. Please provide additional information on the dampers scheduled for replacement.**

See attached damper schedule with the dampers to be replaced highlighted.