



Larry Hogan
Governor

Michael J. Frenz
Executive Director

Members

Thomas E. Kelso
Chairman

Leonard J. Attman
Joseph C. Bryce
Michael Huber
Gary L. Mangum
Manervia W. Riddick
Jodi C. Stanalonis

.....

Procurement

John F. Samoryk
Vice President

Maryland Stadium Authority
The Warehouse at Camden Yards
333 W. Camden Street, Suite 500
Baltimore, MD 21201
410-333-1560
1-877-MDSTADIUM
Fax: 410-333-1888

www.mdstad.com

Voice: 800-201-7165
TTY: 800-735-2258

ADDENDUM No. 6
Structural Steel Painting Services
M&T Bank Stadium
MSA Project No. 22-038

Date Issued: January 20, 2022

This Addendum is hereby made a part of the Contract Documents dated December 21, 2021, on the subject work as though originally included therein. The following amendments, additions, and/or corrections shall govern this work. **This form should be acknowledged below and submitted with the Bids.**

This Addendum incorporates the following items:

1. Question and Answer.

For the upper deck, what is the maximum weight that can be up there and on the ramps? Some of the lifts we were looking into are 23,000lbs.

The concourse and ramps are designed for a 100 psf load or 2,000 lb concentrated load. Equipment heavier than this will require the contractor to provide engineered calculations to see if allowed.

Issued by:

Maryland Stadium Authority
333 W. Camden Street, Suite 500
Baltimore, MD 21201
Sandra Fox, Procurement Officer

Company

Acknowledgment
(Name and Title)

Date